

Viral Filtration Efficiency (VFE) Final Report

Test Article: Filter Composit R57 for R-Shield
 Study Number: 1503530-S01
 Study Received Date: 31 Mar 2022
 Test Started Date: 06 Apr 2022
 Test Finished Date: 12 Apr 2022
 Testing Facility: Nelson Laboratories, LLC
 6280 S. Redwood Rd.
 Salt Lake City, UT 84123 U.S.A.
 Test Procedure(s): Standard Test Protocol (STP) Number: STP0007 Rev 17
 Deviation(s): None

Summary: The VFE test is performed to determine the filtration efficiency of test articles by comparing the viral control counts upstream of the test article to the counts downstream. A suspension of bacteriophage ΦX174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at $1.1 - 3.3 \times 10^3$ plaque forming units (PFU) with a mean particle size (MPS) of $3.0 \mu\text{m} \pm 0.3 \mu\text{m}$. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. The VFE test procedure was adapted from ASTM F2101.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Outside
 Test Area: $\sim 40 \text{ cm}^2$
 VFE Flow Rate: 28.3 Liters per minute (L/min)
 Conditioning Parameters: $85 \pm 5\%$ relative humidity (RH) and $21 \pm 5^\circ\text{C}$ for a minimum of 4 hours
 Positive Control Average: 2.4×10^3 PFU
 Negative Monitor Count: < 1 PFU
 MPS: $3.0 \mu\text{m}$

Results:

Test Article Number	Percent VFE (%)
1	99.8

The filtration efficiency percentages were calculated using the following equation:

$$\% VFE = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request



James Luskin electronically approved
Study Director

James Luskin

13 Apr 2022 19:10 (+00:00)
Study Completion Date and Time